

PRÜFZEUGNIS

Concerning the examination of samples "Mischung T 9673" in accordance with the recommendations 1.3.13 of the German Federal Health Office for materials in contact with drinking water (KTW-recommendations)

Manufacturer : Huber + Suhner AG, Pfäffikon ZH, Schweiz
 Type of the test material : rubber quality (EPDM)
 Brand Name of the test material : "Mischung T 9673"
 Type of the sample : sheets
 Samples received : 06.06.2002
 Sampler : manufacturer

Test results

1. Material composition was confirmed
2. Basic requirements: S:V-ratio 1:25 cm³/cm²

	1. - 3. day	4. - 6. day	7. - 9. day	Standard value for 3. extr.
Clarity, colour, taste, odour, foaming	TON 5 wet mortar	n5a	n6a	Not significantly affected
C-migration [mg C/m ² d]	0	6	5	≤ 60,0
Cl ₂ -consumption [mg Cl ₂ /m ² d]	33	37	30	≤ 75,0

3. Additional requirements:

Amines [mg/m ² d]	0,0079	0,0122	0,0067	
Phenoles [mg/m ² d]	<0,01	<0,01	<0,01	

The examined samples "Mischung T 9673" comply with the requirements of KTW-recommendations of the Federal Health Office in the range of gaskets D1 and D2.
 Reference to the original German test is recommended if necessary.

Karlsruhe, 15.10.2002


 Dr. I. Wagner
 Leiter der Prüfstelle

This certificate expires as determined in the respective standard/certification wherefore it is issued but 5 years after the date of issue at the latest.
 The publication of this test certificate - completely or in parts - is not permitted except of written approval by the test institute

Das Technologiezentrum Wasser ist eine Einrichtung des DVGW Deutsche Vereinigung des Gas- und Wasserfaches e.V.

Geschäftsführer:
 Prof. Dr.-Ing. W. Kühn

Postadresse: Karlsruhe Str. 84
 D-76139 Karlsruhe
 Hauptadresse: Wasserwerkstr. 4
 D-76137 Karlsruhe
 Telefon: +49-(0)721-85163-0
 Telefax: +49-(0)721-33180
 Internet: www.tzw.de

Volksbank Bruhrain-Kraich-Hardt eG
 Adler Str. 1, 68794 Oberhausen
 BLZ 663 916 00 Konto 13191913
 BIC: GENO DE 61 ORH
 IBAN DE 63 6639 1600 0013 1919 13
 Ust.-ID-Nr. (VAT): DE 114 341 970
 Steuer-Nr. 208 5857 0286